

Building Safety Certificate

Certified that the building of "Chail Public School, Village Naugrawn P.O. Chailchowk Tehsil Chachiot, Distt. Mandi (H.P.)" was inspected by the Junior Engineer, Chailchowk Section HPPWD, Sub-Division Gohar, on dated 02.07.2022 and reported that the building is a RCC framed structure with brick masonry walls Public Works Department has never supervised this building during construction at any stage. No detailed structural analysis and drawings in seismic and non-seismic conditions are available/ were provided to check the safety of building. Foundation depth, quality and quantity of material used & cement concrete ratio used is not known to HPPWD department. As per the report of the Pradhan, Gram Panchayat Chachiot Development Block Gohar Distt. Mandi HP , the Chail Public School is continuously running since 01.04.2014. However , presently by visual inspection the said building seems safe for running the School for the academic session 2022-2027 (Five year) under normal loading condition of existing dead and live load of this building except in case of natural calamities i.e earthquake, flood, unequal settlement etc.

Executive Engineer,
Gohar Division (B&R)
HP.PWD.Gohar.

No. PW-GHR-WA-Building safety/2022-

4895-96

Dated 2-7-2022

Copy to the Principal Chail Public School Naugrawn P.O. Chailchowk Tehsil Chachiot, Distt. Mandi (H.P.)"

Copy to the Assistant Engineer Sub-Division HPPWD Gohar w.r.t. his office letter No. 991 dated 01.07.2022 for information.

Executive Engineer,
Gohar Division (B&R)
HP.PWD.Gohar